

16 FT MAX

2 IN

14 #8x3 COURSE THREAD DRYWALL SCREWS FOR 2x4 OR HEAVIER WOOD STUDS

14 #6x1 1/4 (MIN) FINE THREAD DRYWALL SCREWS FOR 20GA OR HEAVIER STEEL STUDS

SURFACE WALL PLATE

MOUNTING TRAY 16 DEGREES MAX

ARM

16 IN

17 IN

2 IN

2 IN

16 IN

4 IN

DRYWALL COVER

2x4 WOOD (1-1/2"x3-1/2") OR LARGER OR 20GA OR HEAVIER 3-1/2" OR LARGER STEEL C STUDS 16 FT LONG (MAX)

FOR 2004 APPROVAL RENEWAL CONTACT WESTBROOK ENGINEERING INC. OR OSHPD

COPYRIGHT © 2001

SHN ENGINEERING CO  
P O BOX 6693 San Mateo CA 94403 (650)349-8727

REGISTERED PROFESSIONAL ENGINEER  
S. H. N. No. 22,846  
Exp. 1/24/01  
CIVIL  
STATE OF CALIFORNIA

THE ENGINEER/ARCHITECT OF RECORD SHALL SUBSTANTIATE THE ADEQUACY OF THE WALL TO MEET OTHER REQUIREMENTS OF TITLE 24:

- 1.0 FIRE PROTECTION
- 2.0 ANY OTHER LOADS
- 3.0 ABOVE FLOOR DEFLECTION ALLOWANCE
- 4.0 SUPPORT OF WALL AND BRACING OF STUDS SHALL BE IN ACCORDANCE WITH THE LATEST CBC
- 5.0 ANCHORAGE OF THE FLOOR AND CEILING TRACKS OR PLATES TO THE SUPPORT STRUCTURE SHALL BE VERIFIED BY THE ENGINEER OF RECORD. OTHER FASTENERS EQUAL OR BETTER MAY BE USED SUBJECT TO OSHPD APPROVAL. CONNECTION DETAILS, DRYWALL OR PLASTER COVERING SHALL BE IN ACCORDANCE WITH CBC.
- 6.0 CONNECTION OF THE TV/MONITOR TO THE BRACKET IS NOT SUBJECT TO REVIEW BY OSHPD.
- 7.0 PROPER INSTALLATION OF THIS SYSTEM SHALL BE THE RESPONSIBILITY OF THE RESPONSIBLE PROFESSIONAL FOR THE BUILDING PROJECT.
- 8.0 THIS IS A PROPRIETARY PRODUCT OF WESTBROOK ENGINEERING, INC. DO NOT FABRICATE.
- 9.0 U.S. PATENT NO. 4,518,751
- 10.0 MAX. LOAD RATING 110 LB

SEPT 2000 COPYRIGHT © 2000

THIS OSHPD APPROVAL IS PENDING

TELEMOUNT SURFACE WALLMOUNT MODEL NOS. SWM13, SWM16, SWM20, SWM27  
MAXIMUM LOAD RATING 110 LB (50Kg)

WESTBROOK ENGINEERING, INC.  
1327 BRANSTEN RD. SAN CARLOS, CA 94070

**D-0498**

16 FT MAX

2 IN

14 #8x3 COURSE THREAD DRYWALL SCREWS FOR 2x4 OR HEAVIER WOOD STUDS

14 #6x1 1/4 (MIN) FINE THREAD DRYWALL SCREWS FOR 20GA OR HEAVIER STEEL STUDS

SURFACE WALL PLATE

MOUNTING TRAY 16 DEGREES MAX

ARM

18 IN

17 IN

2 IN

2 IN

16 IN

3.5 IN

DRYWALL COVER

2x4 WOOD (1-1/2"x3-1/2") OR LARGER OR 20GA OR HEAVIER 3-1/2" OR LARGER STEEL C STUDS 16 FT LONG (MAX)

FOR 2004 APPROVAL RENEWAL CONTACT WESTBROOK ENGINEERING INC. OR OSHPD

COPYRIGHT © 2001

SHN ENGINEERING CO  
P O BOX 6693 San Mateo CA 94403 (650)349-8727

REGISTERED PROFESSIONAL ENGINEER  
S. H. N. No. 22,846  
Exp. 1/24/01  
CIVIL  
STATE OF CALIFORNIA

THE ENGINEER/ARCHITECT OF RECORD SHALL SUBSTANTIATE THE ADEQUACY OF THE WALL TO MEET OTHER REQUIREMENTS OF TITLE 24:

- 1.0 FIRE PROTECTION
- 2.0 ANY OTHER LOADS
- 3.0 ABOVE FLOOR DEFLECTION ALLOWANCE
- 4.0 SUPPORT OF WALL AND BRACING OF STUDS SHALL BE IN ACCORDANCE WITH THE LATEST CBC
- 5.0 ANCHORAGE OF THE FLOOR AND CEILING TRACKS OR PLATES TO THE SUPPORT STRUCTURE SHALL BE VERIFIED BY THE ENGINEER OF RECORD. OTHER FASTENERS EQUAL OR BETTER MAY BE USED SUBJECT TO OSHPD APPROVAL. CONNECTION DETAILS, DRYWALL OR PLASTER COVERING SHALL BE IN ACCORDANCE WITH CBC.
- 6.0 CONNECTION OF THE TV/MONITOR TO THE BRACKET IS NOT SUBJECT TO REVIEW BY OSHPD.
- 7.0 PROPER INSTALLATION OF THIS SYSTEM SHALL BE THE RESPONSIBILITY OF THE RESPONSIBLE PROFESSIONAL FOR THE BUILDING PROJECT.
- 8.0 THIS IS A PROPRIETARY PRODUCT OF WESTBROOK ENGINEERING, INC. DO NOT FABRICATE.
- 9.0 U.S. PATENT NO. 4,518,751
- 10.0 MAX. LOAD RATING 133 LB

SEPT 2000 COPYRIGHT © 2000

THIS OSHPD APPROVAL IS PENDING

TELEMOUNT SURFACE WALLMOUNT MODEL NO. SWM32  
MAXIMUM LOAD RATING 133 Lb (60 Kg)

WESTBROOK ENGINEERING, INC.  
1327 BRANSTEN RD. SAN CARLOS, CA 94070

**D-0499**

ULTIMOUNT CONCRETE WALL OSHPD APPROVED